

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7271-1209:158 Page 1 of 1

**CATEGORY:** Ionization Smoke Detector

**LISTEE:** System Sensor, 3825 Ohio Ave., St. Charles IL 60174  
Contact: \*Trish Linhart (630) 377-6674 Fax (630) 377-7245

**DESIGN:** Models 1251 and 1251B ionization smoke detectors. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as an ionization smoke detectors when used in conjunction with listee's listed Model B210LP, B501, and B501BH bases (CSFM Listing No. 7300-1209:128) and separately listed compatible fire alarm control units.  
Units are suitable for open area protection at air velocities up to 500 fpm for Model1251 and 1200 fpm for Model1251B.

\*Rev. 06-16-2003 JEW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 16, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager